

MGI MODULAR GRAVITY HOOD WITH FILTERS (THROAT SIZES 78" & LARGER)

IM-4720FSL

December 2015

INSTALLATION, OPERATION & MAINTENANCE MANUAL

See Catalog 4720 for sizes that ship assembled.

Qty	Hardware Kit #1B
	Item
40	Cap Screw, Serrated Flange, 1/4-20 x 5/8"
40	Hex Nut, Serrated Flange, 1/4-20

Qty	Hardware Kit #1C
	Item
4	Doubler plates
4	Cap Screw, Serrated Flange, 5/16-18 x 3/4"
4	Hex Nut, Serrated Flange, 5/16-18

Note: Not always required.

Qty	Hardware Kit #3
	Item
A/R	Cap Screw, Serrated Flange, 5/16-18
A/R	Hex Nut, Serrated Flange, 5/16-18


Qty	Hardware Kit #4A
	Item
40	Screws, 12 x 3/8"

Qty	Hardware Kit #4B
	ltem
60	Screws, 12 x 3/8"

Qty	Hardware Kit #4C
	Item
88	Screws, 12 x 3/8"

Qty	Hardware Kit #5
	ltem
A/R	Hood Clips (Only for hood panels longer than 108")

Oto.	Hardware Kit #6B
Ųίγ	ltem
28	Cap Screw, Serrated Flange, 5/16-18 x 3/4"
28	Hex Nut, Serrated Flange, 5/16-18




STEP 1 - BASE ASSEMBLY

Fasteners (Kit #1B and #1C) - Note: There may be extra fasteners.

Lay out the **Curb Cap Side**, **Hood Support Assembly** and **Curb Cap End** in approximate location to each other. See Figure 2. Use (3) 1/4-20 fasteners for 5" base height and (4) 1/4-20 fasteners for 12" base height. Leave top two holes open on the Base End. **Note: Hand tighten only until Step 3.** Bolt together **Curb Cap Sides** to **Hood Support Assembly** with (8) 1/4-20 fasteners per Hood Support Assembly for 5" bases and (10) 1/4-20 fasteners for 12" bases. On some hoods, a **Doubler Plate** is required. See Detail A of Figure 2. For base assemblies with more than one **Hood Support Assemblies**, orient top flanges away from center.


Figure 2.




STEP 2 - HOOD MOUNT BARS

Fasteners (Kit #1B and #1C)

Loosely assemble **Hood Mount Bars** on both sides of the **Base Ends** using (4) 1/4-20 fasteners per side. On hoods using a **Doubler Plate**, mount **Brace** using 5/16-18 hardware. See Figure. 3b.





Brace


STEP 3 - CAULK


Caulk inside corners of base assembly and tighten all fasteners. Install assembly onto roof curb before proceeding. Ensure that assembly is properly anchored to roof curb.

STEP 4 - FILTER RAILS

Fasteners (Kit #6B) – **Note: There may be extra fasteners.**


Attach Filter Channel, Type -A- to the Hood Mount Bar using cap screws and nuts (hand tight). Lay Filter Channel, Type -B- onto assembly and wedge Filter Stop Plate between them and the Base Assembly. Assemble with cap screws and nuts (hand tight).





STEP 5 - FILTERS

Slide filters into assembly and tighten all fasteners.




STEP 6 - HOOD RAILS

Fasteners (Kit #3) - Note: There may be extra fasteners.

For hoods 120" and longer, see Detail A in Figure 7 and bolt together Hood Rail Sections and Rail Backing Plate with 5/16" hardware. Install two Hood Rail Assemblies to the Hood Mount Bars using cap screws and nuts. Do not fully tighten fasteners. They will be tightened in Step 9.


Figure 7.



STEP 7 - HOOD END PANEL

Fasteners (Kit #4B or #4C and Kit #5) - Note: There may be extra fasteners.


Install Male End Panel Assembly using #12 screws.



STEP 8 - HOOD PANELS

Fasteners (Kit #4A or #4B or #4C and Kit #5) - Note: There may be extra fasteners.

Install **Hood Panels** using #12 screws. Place female end of next panel over male end of end panel. See Detail A. On sizes where hood width is 108" and larger, hood clips must be installed at each interlocking rib while installing the panels. Position the **Hood Panel** in place and reach underneath to slide the **Hood Clip** into place. See Detail B. *Figure 10*.



STEP 9 - HOOD END PANEL

Fasteners (Kit #4B or #4C and Kit #5) – Note: There may be extra fasteners.

Install Female End Panel Assembly using #12 screws. Fully tighten the Hood Mount Bar/Side Rail fasteners from Step 6.

